

PRODUCT TYPE REPORT



Sponsor: **Gusclad Ltd**
Ballyfarnon, Boyle
Co. Roscommon
Ireland

Prepared by: **LGAI Technological Center, S.A.**
(APPLUS)
Campus UAB
Ronda de la Font del Carme, s/n
E - 08193 Bellaterra (Barcelona)

Notified Body No: **0370**

Product name: **Gusclad 40 mm panel**

Report n°: **20/23913-3134-1**

Date of issue: **08th January, 2021**

Date at which the sample was received: 25-11-2020

1.- OBJECT OF THE TEST

Test for Determination of the Product Type (DPT) of Reaction to Fire of the construction product UNE-EN 14509-2014 VC-2016: "Self-supporting double skin metal faced insulating panels – Factory made products - Specifications" according to the standard:

- EN ISO 11925-2:2020: "Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test".
- UNE-EN 13823:2012+A1:2016: "Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item".

LGAI TECHNOLOGICAL CENTER, S.A. is notified body n° 0370

This document may only be copied in full. Digital reports with an electronic signature will be considered as an original document, as well as its respective electronic copies. The impression of this document will not have legal validity. This document has 24 pages, of which 13 are annexes. LGAI, Technological Center, S.A. is not responsible for the documentation and/or information provided by the petitioner.

2.-PRODUCT CHARACTERISTICS

Sandwich panels (with Applus code 20/3134) were received with the following indications in accordance with the technical specifications provided by the petitioner:

Product trade name: Gusclad 40 mm panel

PIR panel

The product is composed by 3 layers:

- Layer 1: PVC coated steel (outer sheet), thickness of 0,55 mm, approximate density of 7600 kg/m³, superficial density of 3602 kg/m², olive colour and leather-grain appearance.
- Layer 2: PIR foam (core material), thickness of 40 mm, average density of 41,17 kg/m³, superficial density of 1,79 kg/m² (inc. ribs), yellow colour and light coarse foam appearance.
- Layer 3: Smooth polyester coated steel (inside linear sheet), thickness of 0,38 mm, approximate density of 7600 kg/m³, superficial density of 2744 kg/m², white colour and smooth appearance.

The petitioner did not provide more information.

Fixing system: The test is carried out without substrate.

Manufacturer: Gusclad Ltd, Ballyfarnon, Boyle, Co. Roscommon, Ireland.

3.-MAINTENANCE SPECIFICATION

Not applied.

4. - DESCRIPTION OF THE FINAL CONDITIONS OF USE

The product is intended for use as an exterior building envelope. External wall panel use only.

5. – CONDITIONING

The product conditioning was conducted in compliance with Standard UNE-EN 13238:2011: "Fire Reaction Tests for construction materials. Conditioning procedures and general rules for the selection of substrates".

The samples were stored in a conditioning chamber at 23°C ± 2°C, and at 50% ± 5% relative humidity, until a constant weight was reached.

6.-TESTS

6.1. –Small Burner Test in compliance with standard EN ISO 11925-2:2020

Date at which test was performed: Start: 14-12-2020
End: 15-12-2020

During the tests, the environmental conditions of the laboratory were maintained at temperature of $(23 \pm 5)^{\circ}\text{C}$, and relative humidity of $(50 \pm 20)\%$.

6.1.1. - Method specifications according to final use condition

6.1.1. a) - Flame exposure conditions

The product was treated as a multi-layer product, applying the flame on the surface of the sample in accordance with the specifications in section 7.3.3.1 of the test standard. In addition, the flame was applied to the centre of the width of the bottom edge of the test specimen, to 1,5 mm after the surface, in accordance with the specifications contained in paragraph 7.3.3.2.2. of the test standard. Finally, the flame was applied to the edge placed on 90° sample, in accordance with the specifications contained in paragraph 7.3.3.2.3. of the test standard.

6.1.1.b)- Conditions for flame application: 30 seconds

6.1.1.1.- General procedure based on paragraph 7.

Air velocity in compliance with paragraph 4.2 of the testing standard: 0,7 m/s

SAMPLES	Application of the flame on the surface					
	Lengthwise			Crosswise		
	I	II	III	I	II	III
Duration of inflammation (in s)	-	-	-	-	-	-
Time needed to reach 150 mm (in s)	-	-	-	-	-	-
Ignition of the filter paper (yes/no)	NO	NO	NO	NO	NO	NO

(-) no inflammation has occurred during the test

SAMPLES	Application of the flame on the edge at 1,5 mm					
	Lengthwise			Crosswise		
	I	II	III	I	II	III
Duration of inflammation (in s)	-	-	-	-	-	-
Time needed to reach 150 mm (in s)	-	-	-	-	-	-
Ignition of the filter paper (yes/no)	NO	NO	NO	NO	NO	NO

(-) no inflammation has occurred during the test

Remarks

During the test, no inflammation of the product nor fall of inflamed material on the filter paper was observed.

Measurement uncertainty

Not applicable, since it is not measured.

SAMPLES	Application of the flame on the edge at 90° (PIR foam)					
	Lengthwise			Crosswise		
	I	II	III	I	II	III
Duration of inflammation (in s)	3,0	2,0	4,0	3,0	3,0	3,0
Time needed to reach 150 mm (in s)	-	-	-	-	-	-
Ignition of the filter paper (yes/no)	NO	NO	NO	NO	NO	NO

(-) no inflammation has occurred during the test

Remarks

During the test, a small ignition was observed without reaching 150 mm and any fall of material onto the filter paper.

Uncertainty of measurement

± 1,2 s

6.2.2.2.-**SMOGRA (in m²/s²)**

This is defined as the maximum value of the quotient $SPR_{av}(t) / (t-300)$, multiplied by 10,000. The quotient is only calculated for the part of the time of exposure during which the levels of the thresholds for SPR_{av} and TSP were exceeded.

If one or the two threshold values are not exceeded during the period of exposure, the SMOGRA value equals zero.

TSP₆₀₀ (in m²)

This is the total amount of smoke released by the sample during the first 600 s (10 minutes) from the beginning of the exposure to the main burner.

SPR (in m²/s): This is the smoke production velocity.

6.2.3.–Mounting specifications

Each test set consists of two items:

1 part measuring 1,500 x 495 mm, which is representative of the short wing, and
1 part measuring 1,500 x 1,000 mm, representative of the long wing, in accordance with the specifications contained in paragraph 5.1.1.

The samples were assembled by the petitioner, forming a corner according to the specifications of UNE-EN 14509-2014 VC-2016 standard.

The corresponding panel to the long wing, displays vertical joint according to the point 5.2.2. e) of the standard.

The test was carried out removing the lateral bottom plates of the test wagon, according to section 5.2.2 a) of the teste standard and with 40 mm separation between the back of the sample and the backing board.

6.2.4.–Test Results

6.2.4.1. –Sample n°1

Environmental conditions at the beginning of the test:

Temperature: **16 °C**

HR: **53 %**

Pressure: **99927 Pa**

Level of exposure of the burner (kW): **31,47**

INDEXES

FIGRA_{0.2 MJ} (W/s)	59,95
FIGRA_{0.4 MJ} (W/s)	54,87
LFS	<to edge
THR_{600s} (MJ)	2,33
SMOGRA (m²/s²)	14,10
TSP_{600s} (m²)	91,94
Release of inflamed material in 600 s	NO

Conditions at the end of the test:

Temperature: **16 °C**

HR: **53 %**

Pressure: **99967 Pa**

Light transmission (%): **99,29 %**

O₂ Concentration (%): **20,94 %**

CO₂ Concentration (%): **0,01 %**

6.2.4.2.-Sample n° 2

Environmental conditions at the beginning of the test:

Temperature: **15 °C**

HR: **53 %**

Pressure: **99981 Pa**

Level of exposure of the burner (kW): **31,23**

INDEXES

FIGRA_{0.2 MJ} (W/s)	74,85
FIGRA_{0.4 MJ} (W/s)	74,85
LFS	<to edge
THR_{600s} (MJ)	3,41
SMOGRA (m²/s²)	19,21
TSP_{600s} (m²)	114,24
Release of inflamed material in 600 s	NO

Conditions at the end of the test:

Temperature: **14 °C**

HR: **55 %**

Pressure: **100159 Pa**

Light transmission (%): **99,56 %**

O₂ Concentration (%): **20,94 %**

CO₂ Concentration (%): **0,01 %**

6.2.4.3.-Sample n°3

Environmental conditions at the beginning of the test:

Temperature: **13 °C**

HR: **57 %**

Pressure: **99998 Pa**

Level of exposure of the burner (kW): **31,79**

INDEXES

FIGRA_{0.2 MJ} (W/s)	66,69
FIGRA_{0.4 MJ} (W/s)	66,69
LFS	<to edge
THR_{600s} (MJ)	3,82
SMOGRA (m²/s²)	19,13
TSP_{600s} (m²)	105,85
Release of inflamed material in 600 s	NO

Conditions at the end of the test:

Temperature: **14 °C**

HR: **57 %**

Pressure: **100097 Pa**

Light transmission (%): **99,62 %**

O₂ Concentration (%): **20,95 %**

CO₂ Concentration (%): **0,02 %**

6.2.5.- Visual observations

The observation of released material or of inflamed particles during the first 10 minutes of the test lead to the attribution of the identification sub-index "d" to the material, so that:

d0: No release of inflamed material is observed.

d1: release of inflamed material with a ≤ 10 s flame persistence.

d2: Release of inflamed material with a > 10 s flame persistence.

No propagation of the side flame over the long wing, or release of inflamed material is observed in any of the three tested samples.

6.2.6.- Uncertainty associated to the measurement equipment

Set of thermocouples of the extraction pipe	$\pm 2^{\circ}\text{C}$
Pressure transmitter of the pipe	± 2 Pa
Smoke measuring device	$\pm 5\%$
Ambient pressure measuring equipment	$\pm 5\%$
Ambient humidity measuring device	$\pm 5\%$
Ambient temperature measuring device	$\pm 2^{\circ}\text{C}$

6.3.- Results

6.3.1.- EN ISO 11925-2:2020

	Flame propagation	Paper inflammation
Application of the flame on the surface	Fs < 150 mm in 60 seconds	NO
Application of the flame on the edge – 1.5 mm	Fs < 150 mm in 60 seconds	NO
Application of the flame on the edge – 90°	Fs < 150 mm in 60 seconds	NO

6.3.2.- UNE-EN 13823:2012+A1:2016

SAMPLES	I	II	III	Average
FIGRA_{0.2 MJ} (W/s)	59,95	74,85	66,69	67,16
FIGRA_{0.4 MJ} (W/s)	54,87	74,85	66,69	65,47
LFS	<to edge	<to edge	<to edge	< to edge
THR_{600s} (MJ)	2,33	3,41	3,82	3,19
SMOGRA (m²/s²)	14,10	19,21	19,13	17,48
TSP_{600s} (m²)	91,94	114,24	105,85	104,01
Release of inflamed material in 600 s	NO	NO	NO	NO

The test results correspond to the behaviour of test samples of a product under the testing conditions themselves. They do not intend to be the only evaluation criterion to assess the potential fire hazard involved in the use of the product.

The Euro class to which the tested product belongs is defined in the Classification Report.

Laboratory Manager
 LGAI Technological Center S.A. (APPLUS)

Technician Responsible of Euroclasses
 LGAI Technological Center S.A. (APPLUS)

The results refer exclusively to the samples tested at the time and under the conditions indicated.

The uncertainties expressed in this document pertain to the expanded uncertainty, which has been obtained by multiplying the typical measurement uncertainty by the coverage factor k=2 which, for a regular distribution, corresponds to a coverage probability of approximately 95%.

Applus+ guarantees that this task has been carried out in compliance with the requirements of our Quality and Sustainability System, and furthermore, that the contractual terms and legal regulations have been complied with. In the framework of our improvement programme, we would appreciate any comments you may deem appropriate. These should be addressed to the manager who signs this document, or to the Quality Director of Applus+, at the following address: satisfaccion.cliente@applus.com

ANNEXES

7.-PHOTOGRAPHS

8.-CHARTS

7.-PHOTOGRAPHS



Photo n°1: Detail of the corner assembly, upper view.



Photo n°2: Detail of the vertical side edge of the long wing, some 500 mm from the bottom of the support.



Photo n°3: View of the corner and anchoring system.



PHOTO N°4: View of the product prior to starting the test.



PHOTO N°5: Sample 1 – Flame attack approx. 10 minutes after the start of the test.



PHOTO N°6: Sample 1 – State of the product upon completion of the test.



PHOTO N°7:Sample no. 2 - Flame attack approx. 10 minutes after the start of the test.



PHOTO N°8: Sample 2 – State of the product upon completion of the test.



PHOTO N°9: Sample 3 – Flame attack approx. 10 minutes after the start of the test.




PHOTO N°10: Sample 3 – State of the product upon completion of the test.

8.- CHARTS

Sample nº1 – Ratios related to the release of heat and smoke

Sample nº2 – Ratios related to the release of heat and smoke

Sample nº3 – Ratios related to the release of heat and smoke



NORMA: UNE-EN 13823:2012 + A1:2016
STANDARD

Data del test: 15:12:20 20:04
Test date

Nom del fitxer: 3134mostra1
File name

Descripció: -
Description

Client: GUSCLAT
Client


Material: -
Material

Pes (kg/m²): -
Weight(kg/m²)



Gruix: -
Thickness





HRR av: 31.47 kW

THR 600s: 2.33 MJ
FIGRA 0,2MJ: 59.95 W/s
FIGRA 0,4MJ: 54.87 W/s



TSP 600s: 91.94 m²
SMOGRA: 14.10 m²/s²





NORMA: UNE-EN 13823:2012 + A1:2016
STANDARD

Data del test: 15:12:20 21:04
Test date

Nom del fitxer: 3134mostra2
File name

Descripció: -
Description

Client: GUSCLAT
Client

Material: -
Material





Pes (kg/m²): -
Weight(kg/m²)

Gruix: -
Thickness

HRR av: 31.23 kW

THR 600s: 3.41 MJ
FIGRA 0,2MJ: 74.85 W/s
FIGRA 0,4MJ: 74.85 W/s

TSP 600s: 114.24 m²
SMOGRA: 19.21 m²/s²



NORMA: UNE-EN 13823:2012 + A1:2016
STANDARD

Data del test: 15:12:20 22:04
Test date

Nom del fitxer: 3134mostra3
File name

Descripció: -
Description

Client: GUSCLAT
Client

Material: -
Material

Pes (kg/m²): -
Weight(kg/m²)

Gruix: -
Thickness

HRR av: 31.79 kW

THR 600s: 3.82 MJ
FIGRA 0,2MJ: 66.69 W/s
FIGRA 0,4MJ: 66.69 W/s

TSP 600s: 105.85 m²
SMOGRA: 19.13 m²/s²